

Wilmes Lake Alum Treatment Facility

South Washington Watershed District City of Woodbury - Minnesota 2024 MESERB Summer Conference June 13, 2024

6/13/2024

Agenda


- Location & Background
- Project Description
- Project Goals
- Recommended Improvements
- Construction Status

Location

South Washington Watershed District

 Established in 1984 to manage the resources of the watershed


- Located in Washington County
- Southeast of St. Paul, MN
- Intersects 10 municipalities





Background

- Watershed area of 3,242 acres
- North Wilmes Lake is listed on Minnesota's 303d list as impaired for TP
- 2018 lake management plan set a TP reduction goal of 153 lbs/yr
- 2019 regional alternative analysis identified regional treatment facility





Background

- Previous study considered alternative methods for achieving the desired TP reduction.
- Alum treatment was recommended
- 2020 HR Green alternatives analysis for implementing chemical treatment
- Treat 1-3 cfs of inflow resulting in expected removal rates of 95-283 lbs TP/yr





Figure 4: Kargel Park TP removal options compared to the North Wilmes Lake reduction goal

Project Goals

- Improve water quality of Wilmes Lake
- Blend into park's natural setting
- Provide natural habitat
- Maintain pedestrian connectivity
- Partner with the City for operations and maintenance






Project Description

Considerations:

- Ferric Chloride vs. Aluminum Sulfate
- Site layout
- Treatment facility with a lift station, forcemain and settling basin



Project Description

How does it work?


- Coagulation
- Flocculation
- Sedimentation

$$AI(SO_4)_2$$

$$AI^{+3} + 6 H_2O AI (H_2O)_6^{3+}$$


 $AI^{3+} + H_2O \rightleftharpoons intermediate reactions \rightleftharpoons AI(OH)_3(s) + H^+$





Lift Station

- ▶ Triplex submersible station
- ► Each pump rated for 1cfs (448gpm)
- Median flow within channel: 1.3 cfs
- Mean flow with channel: 3.2cfs
- Flows monitored by SWWD
- ► SAFL Baffle installed upstream of pumps



Lift Station

- Triplex submersible station
- ► Each pump rated for 1cfs (448gpm)
- ► Median flow within channel: 1.3 cfs
- ► Mean flow with channel: 3.2cfs
- Flows monitored by SWWD
- ► SAFL Baffle installed upstream of pumps




Photo Credit: Upstream Technologies



Lift Station

- Triplex submersible station
- ► Each pump rated for 1cfs (448gpm)
- Median flow within channel: 1.3 cfs
- ► Mean flow with channel: 3.2cfs
- ► Flows monitored by SWWD
- SAFL Baffle installed upstream of pumps



Lift Station

- ► Triplex submersible station
- ► Each pump rated for 1cfs (448gpm)
- Median flow within channel: 1.3 cfs
- Mean flow with channel: 3.2cfs
- Flows monitored by SWWD
- ► SAFL Baffle installed upstream of pumps





Settling Basin

- ► ~130,000 CF storage
- ▶ 37 hours detention time @ 1cfs
- ▶ 2' clay liner required



Chemical Building

- Needed to be visually pleasing
- ▶ Blend into park setting
- Low lighting for wildlife
- Permeable pavement
- Non-reflective tin roof







Chemical Building

- Needed to be visually pleasing
- Blend into park setting
- Low lighting for wildlife
- Permeable pavement
- Non-reflective tin roof











- ▶ Lift station constructed awaiting pump installation
- Basin grading complete
- Building foundation complete
- ► Storm sewer piping is in
- ► Landscaping to be completed in spring/summer 2024



Wilmes Lake Alum Treatment Facility South Washington Watershed District

6/13/2024



































Wilmes Lake Alum Treatment Facility South Washington Watershed District

6/13/2024




























Site Restoration







System Operation

- Dredging will be required in the future
- Sludge to be monitored
- Public notices will be posted explaining the process
- Sampling
 - **TSS**
 - ▶ pH
 - ► Total Phosphorus



Design Collaboration







Wilmes Lake Alum Treatment Facility South Washington Watershed District

6/13/2024

Permitting

- ▶ DNR considered a public water need public waters permit – applies to improvements below OHWL
- DLI building, plumbing and site permit review
- MPCA NPDES Permit waste water discharge permit
- ► MCES sludge disposal



Questions



Bridget Osborn, P.E., CFM

Project Manager 651-569-7773 bosborn@hrgreen.com

Kyle Sandberg, P.E., PhD

Project Engineer 651-569-7712 ksandberg@hrgreen.com

